

Electrical Passive Fire Protection for Food and Dairy

Substations · Spray Drying & Cooking · Ammonia Refrigeration · Packaging Warehouses · Safety-Critical Circuits

Section A | Electrical Zone-Wise Fire Risk Map

A1. Substations, MCC Rooms & Cable Galleries

Main substation, boiler / utility MCC, spray-drying tower electrical, ammonia refrigeration plant, cold-storage motor control, cooking / frying and bakery oven MCCs, packaging and CIP MCCs, finished-goods warehouse and central control. Combustible powder dust (spray dryer), ammonia (refrigeration) and Class A high-hazard fire load (carton warehouse) drive the design basis.

| Area | Fire Scenario | Stanvac PFP Product Application | Rating / Priority |
|--|--|--|-------------------|
| Main substation | Transformer + cable fire | Cable coatings, firestops, panel FP | 3 hr / Critical |
| Boiler / utility electrical | Fuel + lagging fire exposure | Cable coatings, firestops, panel FP | 2-3 hr / Critical |
| Spray-drying tower MCC | Combustible powder dust deflagration | Cable coatings, panel FP, firestops | 2 hr / Critical |
| Ammonia refrigeration plant electrical | NH ₃ leak + electrical ignition | Panel FP (corrosion-resistant), cable coatings | 2 hr / Critical |
| Cold-storage motor control | Insulation + PUF panel fire | Cable coatings, firestops, panel FP | 2 hr / High |
| Cooking / frying area MCC | Cooking oil pool / vapour fire | Panel FP, cable coatings | 2 hr / Critical |
| Bakery oven electrical | Heater + flour dust | Panel FP, cable coatings | 2 hr / High |
| Packaging / shrink-wrap MCC | Heater + film fire | Panel FP, cable coatings | 2 hr / High |
| CIP chemical dosing MCC | Caustic / acid + electrical | Panel FP (corrosion-resistant), cable coatings | 2 hr / High |
| Finished goods / carton warehouse | Class A high-hazard fire load | Cable coatings, fire-survival cabling, firestops | 3 hr / Critical |
| Cable galleries (utility → process) | Propagating cable fire | Cable coatings + transverse firestops every 30 m | 3 hr / Critical |
| DG room | Diesel pool fire | Cable coatings, firestops, panel FP | 2-3 hr / Critical |
| CCR / DCS | Panel + cable fire | Panel FP, firestops, FR doors | 2 hr / Critical |

A2. Safety-Critical Electrical Systems

These systems must remain operational throughout the fire event in order to control or extinguish it. Fire-survival cable integrity is mandatory under IEC 60331-21 and BS 6387 CWZ; failure to specify is a non-compliance under NBC Part 4 — Fire and Life Safety.

| Area | Fire Scenario | Stanvac PFP Product Application | Rating / Priority |
|---|---------------------------------------|----------------------------------|--|
| Fire water pump house | Must survive the fire it fights | Fireproofed structure, FR cables | 3 hr / Critical |
| Spray dryer CO ₂ / N ₂ inerting | Inert-gas release on dust event | Fire-survival cable | IEC 60331 / BS 6387 CWZ / Non-negotiable |
| Ammonia leak detection + emergency vent | NH ₃ detector to vent fan | Fire-survival cable, panel FP | IEC 60331 / BS 6387 CWZ / Non-negotiable |
| Cooking hood suppression release | Hood detector to wet-chemical release | Fire-survival cable | IEC 60331 / BS 6387 CWZ / Non-negotiable |
| Warehouse sprinkler pump power | Switchgear to motor | Fire-survival cable | IEC 60331 / BS 6387 CWZ / Non-negotiable |
| Cold store emergency lighting + man-trap | Door release + lighting | Fire-survival cable | BS 6387 CWZ / Critical |
| Emergency DG start & transfer | Battery to engine panel | Fire-survival cable | BS 6387 CWZ / Critical |
| Emergency lighting + PA / GA | Plant-wide egress | Fire-survival cable | BS 6387 CWZ / Critical |

Section B | Product-to-Application Matrix

This section maps each of the four priority Stanvac product lines to the specific food and dairy locations and circuits where they must be specified. Use these tables to build the bill of quantities (BOQ) for any food and dairy opportunity.

B1. Cable Coatings — Fire Propagation Prevention

Minimum 240 minutes protection, thickness ≤ 1.6 mm DFT.

Purpose: prevent the spread of fire along cable trays, risers and bunches. The “Browns Ferry” scenario — one cable igniting an entire cable gallery — is the design basis.

Applicable standards: IEC 60332-3 (FM 3971 has limited use — it provides only short-duration protection against arcs and sparks)

| Zone | Specific Application | Priority |
|---------------------------------------|---|----------|
| Spray-dryer hall cable trays | All HT/LT trays + transverse firestops every 30 m | Critical |
| Ammonia plant cable routes | Compressor, condenser, pump (corrosion-resistant) | Critical |
| Cold-storage cable routes | Lighting + motor | High |
| Cooking / frying area cable routes | Hood, drive, lighting | Critical |
| Bakery oven cable routes | Heater + control | High |
| Packaging line cable routes | Drive + heater | High |
| CIP / chemical dosing cable routes | All cables in chemical zones | High |
| Finished goods warehouse cable routes | Lighting + sprinkler | Critical |
| Main substation cable gallery | Incoming and outgoing | Critical |

| Zone | Specific Application | Priority |
|-----------------------|----------------------------|----------|
| DG room cable entries | Start, alternator, control | Critical |

B2. Cable Coatings — Fire Survivability

240-minute circuit integrity, thickness ≤ 1.6 mm DFT.

Purpose: keep the cable electrically functional while burning, so the safety circuit continues to operate through the fire event. Fire-survival coatings are specified where loss of the circuit would defeat the fire-fighting or shutdown system itself.

Applicable standards: IEC 60331-21 and IS 17505-1

| Circuit Type | Where Applied | Priority |
|--|----------------------------------|----------------|
| Fire water pump power (electric + diesel) | Switchgear to motor | Non-negotiable |
| Spray dryer inerting release circuit | ESD to inert-gas valve | Non-negotiable |
| Ammonia leak detection + vent fan | Detector to vent fan motor | Non-negotiable |
| Cooking hood suppression release | Detector to suppression actuator | Non-negotiable |
| Warehouse sprinkler pump power | Switchgear to motor | Non-negotiable |
| Emergency lighting + PA / GA | Plant-wide egress | Critical |
| UPS feeders to DCS | UPS to marshalling | Critical |
| Emergency DG start & transfer | Battery to engine panel | Critical |
| Cold-store door release & emergency lighting | Trapped-person egress | Critical |

B3. Electrical Panel Fireproofing

Purpose: protect field control panels, junction boxes, MCC panels and logic cabinets from external fire and internal electrical fire. Stanvac offers three complementary solutions under this product line.

| Option | Stanvac Solution | Description & Typical Use |
|--------|--|--|
| A | Two-hour rated firestop sealant | For sealing cable gland openings, panel cut-outs, conduit entries and small penetrations at the panel boundary. Silicone / acrylic intumescent sealant certified to UL 1479 / IS 12458 at 2-hour rating. |
| B | Non-combustible intumescent paint | For external coating of panel enclosures, cable glands and junction boxes exposed to radiant heat or hydrocarbon fire. Non-combustible base with intumescent top-coat. |
| C | Two-hour rated intumescent translucent coating for small-dia. cables (aerosol spray) | Aerosol-delivered translucent intumescent coating for small-diameter instrumentation, control and signal cables entering panels. Clean application in congested panel interiors; 2-hour rated. |

B4. Two-Hour Rated Firestop Barriers

Hybrid combination of mineral wool and firestop mortar.

Purpose: seal every penetration through a fire-rated wall, floor or cable tunnel so compartmentation is maintained. Stanvac's hybrid system combines high-density mineral wool (for bulk void filling and thermal insulation) with firestop mortar (for load-bearing, smoke-tight surface seal). This dual-material approach delivers superior 2-hour rating performance across a wider range of penetration sizes than single-material systems.

Applicable standards: UL 1479 · ASTM E814 · IS 12458

| Location | Specific Application | Priority |
|--|--|----------------|
| Spray-dryer hall boundary | Cable, pipe, duct penetrations | Critical |
| Ammonia plant boundary | Cable and pipe penetrations (NH ₃ -rated) | Critical |
| Cold-storage envelope | Cable and pipe penetrations through PUF | Critical |
| Cooking / frying area boundary | Hood ducting, cable, pipe penetrations | Critical |
| Finished goods warehouse perimeter | Every wall, floor, duct penetration | Critical |
| CIP / chemical room compartment walls | Corrosion-resistant firestops | High |
| Main substation cable trench to building | Sand-seal + firestop pillows + mortar | Critical |
| Cable tunnel transverse barriers | Every 30–50 m | Critical |
| DG room boundary | Fuel and cable penetrations | Critical |
| Fire water pump house entries | Power and control cable penetrations | Non-negotiable |
| HVAC duct penetrations | Fire dampers + collar seals | High |

Detailed product data sheets, certifications, specimen specifications and project BOQ support are available on request.

For more information, please connect with us.